

GPD 315 Inverter Programming Instructions

1. Press the DSPL key until you light up the Program window on the Digital operator. This will display an N number relating to a parameter value.
2. Press the key and arrow up or down to display the parameter number you wish to change.
3. Press the data enter key, then arrow up or down to change the present value.
4. Press and hold that data enter key for about 2 seconds to save the data.
5. Press display key to return to run mode. This will light up FREF under the digital display.

